

CERTIFICATE OF COMPLIANCE

Project title	Tek Stump
Revaro job number	1124
Certification number	1124-CERT-002
Asset/device description	85mm square concrete stumps
Asset/device location	For non-cyclonic building use
References	NA
Client name	Stump Systems
Compliance scope	Review of stump design to applicable standards.
Scope exclusions	Product development and testing Safe design assessment
Assumptions made	Loading and bearer fixings as determined by AS1684.
Applicable standards	Building Act 1993, Nation Building Code, AS 1170, AS 1684, AS 2870, AS 3600, AS 4055, AS 4600
Special conditions	<ul style="list-style-type: none">• Floor live load not to exceed 1.5kPa• Soil bearing capacity to be not less than 75kPa
Compliance validity	3 years
Certifier	Jason Fankhauser, Senior Engineer
Certifier's signature	
Date	6 October 2021
Certifier's postnominals	BE Mech, Grad Dip Eng (Struct) IP, Ass Dip Eng (Design), Grad Cert (Law), Grad Cert (Mgt),
Certifier's registrations	MIEAust CPEng 981072, RPEQ 11617

